	<b>National declaration of performance</b>	<b>Number: 32/KAN-DWU/21E</b>
	KAN-therm Push Platinum System PE-Xc/Al/PE-HD multilayer pipes	Page 1 z 2

1. Name and trade name of building product:

KAN-therm Push Platinum System PE-Xc/Al/PE-HD multilayer pipes [Ø16-32 mm]

2. Designation type of building product:

Push Platinum PE-Xc/Al/PE-HD multilayer pipe

3. Intended use or uses:

For use in indoor installations of cold and hot utility water, drinking water, central radiator and underfloor heating and installations using glycol water solutions in accordance with the "Designer's and contractor's guide" issued by KAN Sp. z o.o., the catalog of the KAN-therm System and the guidelines of the KAN Technical Department.

4. Name and address of the producer and place of manufacture:

KAN Sp. z o.o.  
Zdrojowa 51 PL-16-001 Białystok-Kleosin  
Poland  
[www.kan-therm.com](http://www.kan-therm.com) e-mail: [kan@kan-therm.com](mailto:kan@kan-therm.com)

5. Name and address of the authorized representative, if appointed: Not applicable

6. National system used for assessment and verification of performance constancy:

System 3 and 4

7. National technical specification:

7a. Polish product standard:


PN-EN ISO 21003-2:2009/A1:2011- Multilayer piping systems for hot and cold water installations inside buildings - Part 2: Pipes.

Name of the accredited laboratory and accreditation number:

IMA Materialforschung und Anwendungstechnik GmbH, accreditation DAkkS nr D-PL-13119-02-00

7b. National technical assessment:

Not applicable.

	<b>National declaration of performance</b>	<b>Number: 32/KAN-DWU/21E</b>
	KAN-therm Push Platinum System PE-Xc/Al/PE-HD multilayer pipes	Page 2 z 2

8. Declared performance:

Essential characteristics of the construction product for the intended use or uses	Declared performance	Remarks
Geometric features	Accordance to KAN specifications and PN-EN ISO 21003-2:2009	
Mechanical properties	Design internal pressure resistance determined in accordance with PN-EN ISO 21003-2:2009/A1:2011 Class 1-5 /10 bar	
Physical properties	Thermal stability : PN-EN ISO 21003-2:2009+A1:2011, pkt 10.2  class 1 – T = 60 °C /T <sub>max</sub> = 80 °C class 2 – T = 70 °C /T <sub>max</sub> = 80 °C class 4 – T = 60/ °C T <sub>max</sub> = 70 °C class 5 – T = 80 °C /T <sub>max</sub> = 90 °C	
Marking	Accordance to: PN-EN ISO 21003-2:2009/A1:2011	
Reaction to fire	Class E	
Impact on drinking water	Approved for contact with drinking water	Hygienic certificate PZH B-BK-60210-1265/19, PCA accreditation Nr AB 509

9. The performance of the product described above is in accordance with all of the declared performance characteristics mentioned in point 8. This national declaration of performance is issued in accordance with the Act of 16 April 2004 regarding construction products, under the sole responsibility of the manufacturer.

On behalf of manufacturer signed by:

Manager of the Quality Assurance Department



Kleosin – 10.06.2021  
(place – date of issue)

Janusz Żukowski  
(signature)